

Mission:

To protect, promote & improve the health of all people in Florida through integrated state, county & community efforts.



Ron DeSantis  
Governor

Scott A. Rivkees, MD  
State Surgeon General

Vision: To be the Healthiest State in the Nation

---

## Non-Potable Well Construction, Repair, and Abandonment General Conditions

The following conditions must be met in addition to the requirements of the permit application to construct, repair, modify, or abandon a non-potable well:

1. The well contractor shall meet the well setback/spacing requirements of Chapter 62-532, F.A.C., Table 1. Any variance from these setbacks shall be approved in advance by the appropriate regulating agency.
2. The well contractor shall keep a copy of this permit on-site during all phases of well construction, repair, or abandonment.
3. The well contractor shall affix a District-approved permanent identification tag to this well as prescribed in Chapter 40C-3.461 (3), F.A.C.
4. The well contractor shall submit to the District a Well Completion Report in a District-approved format within 30 days of the completion of the construction, repair, or abandonment authorized by this permit.
5. The well contractor shall meet all well construction requirements as outlined in Chapters 40C-3 and 62-532, Florida Administrative Code.
6. The upper terminus of the well casing must be at least 12 inches above finished grade per Chapter 62-532.500(3)(b), Florida Administrative Code. Well "tees" and "elbows" may not be installed off the casing at an elevation less than 12 inches above finished grade.
7. Irrigation from this well is prohibited between the hours of 10:00 a.m. and 4:00 p.m., except as outlined in the St. Johns River Water Management District water conservation rules, enacted July 23, 1991.
8. Issuance of this permit does not relieve the well owner of obtaining any necessary federal, state, local or special District permits or authorizations.
9. Permit issuance does not guarantee water quantity or quality.